



UNIVERSITY OF KERALA

CENTRAL LABORATORY FOR INSTRUMENTATION AND FACILITATION (CLIF)
Kariavattom Campus, Thiruvananthapuram, Kerala, India - 695 581

Dr. G Prasad Hon. Director E-mail: siccuok@gmail.com Website: www.keralauniversity.ac.in

Phone: 0471-230856

No. CLIF/PUR/312/2019-20

13.01.2020

QUOTATION NOTICE

Sealed Quotations are invited for purchasing Dehumidifiers with following Specifications by Central Laboratory for Instrumentation and Facilitation, University of Kerala, Kariavattom.

1	Name of Items	Supply of, Industrial Dehumidifier – 4 No. for Central Laboratory for Instrumentation and Facilitation University of Kerala, Kariavattom Campus.	
2	Documents to be submitted.	 Technical Bid. Address and Details of the Firm. GST Registration details. Technical Details/Specification Items and Switch. Any other relevant information Financial Bid Financial quote. 	
3	Period of Completion	10 Days	
4	Last Date of receipt of Tender/Bid closing	23.01.2020 3 PM	
5	Date and time of opening Bid	23.01.2020 3 30PM	

Industrial Dehumidifier - 4 no.

Technical Specification				
Power Supply (V/Hz)	240V/50Hz			
Moisture Removal 30C, RH 80%(L/Day)	100 LPD			
Material	Ultra-Finished Powder Coated Steel			
power Consumption (KW)	1.2 KW			
Capacity Air Flow Volume (CMH)	1100			

Operating Temperature Range °C	5-35°C	
perating remperation		
Warranty – Minimum one year		
Powdered Coated Steel body		
a . 1 Operation	1 Lastings Con	tinuous drain
Operating Range 16% to 90% RH with for added convenience	% Incremental settings Con	
Removable air filter		
Auto shut off feature prevents water from	n overflowing	
Power indicator		
Carry handle and casters		
Ideal for Medium size room	1	;
Attractive and contemporary design enh	ances any home	
Environment friendly Refrigerant		

The **Dehumidifier** should be delivered and installed at the Central Laboratory for, Instrumentation and Facilitation, University of Kerala, Kariavattom.

The quotes should be inclusive of cost, freight, taxes, loading unloading etc.

Terms and conditions of warranty should be clearly mentioned.

The Quotations should reach to "The Director, Central Laboratory for Instrumentation and Facilitation, University of Kerala, Kariavattom".

Kindly include a Compliance Statement also

Hon Director,

Central Laboratory for Instrumentation and Facilitation, University of Kerala,

Kariavattom

