



## UNIVERSITY OF KERALA

Thiruvananthapuram, Kerala, India – 695034

(Established as University of Travancore by the Travancore University Act in 1937 and reconstituted as University of Kerala by the Kerala University Act of 1957 and presently governed by the Kerala University Act of 1974 passed by the Kerala State Legislative Assembly)  
(Re-accredited by NAAC with 'A' Grade)

13979/Admn B  
IV/2022/UOK

07.04.2022

### QUOTATION NOTICE

Competitive Quotations are invited from interested Vendors within Kerala state, for the supply of one number of 5 KVA Online UPS for use in the IT Cell (Exams) of the University Office, Palayam (Specification Appended).

#### Conditions

1. The rate quoted should be inclusive of Tax, transportation charges, installation charges and any other charges.
2. Complaints if any with the items supplied should be rectified/replaced to the satisfaction of the University by the suppliers at their own cost.
3. Payment will be made only after the supply of the items at our own site.
4. The undersigned reserves the right to accept/reject any quotation without assigning any reason.

The sealed quotations should be addressed to the undersigned superscribing "**Quotations for the supply of one number of 5 KVA Online UPS for use in the IT Cell (Exams) of the University Office**". The last date for receipt of quotations is at 3.00 PM on 20.04.2022. The quotations will be opened at 3.30 PM on the same day in the presence of Vendors then present.

**Dr. K S Anil Kumar**  
Registrar



**Specification for 5.0KVA Online UPS**

<b>Rating in KVA</b>	<b>: 5.0KVA Online UPS</b>
<b>Technology</b>	<b>: IGBT- PWM with inbuilt isolation Transformer.</b>
<b>Input Power</b>	<b>: Single phase 160V-260V pure sine wave 50Hz.</b>
<b>Output Power</b>	<b>: Single phase 230V+/-1% pure sine wave 50Hz.</b>
<b>Battery type</b>	<b>: SMF (with rack)</b>
<b>Backup time</b>	<b>: 1 Hour full load.</b>
<b>Overall Efficiency</b>	<b>: 90%</b>
<b>Warranty</b>	<b>: 3Year UPS &amp; Battery</b>

