



UNIVERSITY OF KERALA

Thiruvananthapuram, Kerala, India – 695034

(Established as University of Travancore by the Travancore University Act in 1937 and reconstituted as University of Kerala by the Kerala University Act of 1957 and presently governed by the Kerala University Act of 1974 passed by the Kerala State Legislative Assembly)

(Re-accredited by NAAC with A++ Grade)

28572/Admn B IV/2026/UOK

11.08.2026

QUOTATION NOTICE

Competitive quotations are invited from eligible vendors within Kerala for the **supply, installation, and commissioning of six (6) numbers of 12 V, 65 Ah SMF batteries with interconnecting cables (3 year warranty)** for the **3 KVA UPS** installed in the ground floor of **Finance Wing, SH Campus, Palayam**, on a **buy-back basis (Buyback items: EXIDE POWERSAFE PLUS 12V 65 Ah-5 nos)**. The technical specifications and the format of the Compliance Statement are appended.

Conditions

1. The rate quoted should be inclusive of Tax, transportation charges, installation charges and any other charges.
2. Compliance Statement should be submitted that includes all parameters as in specification.
3. Complaints if any with the items supplied should be rectified/replaced to the satisfaction of the University by the suppliers at their own cost.
4. Installation with necessary accessories should be done by the supplier/OEM.
5. Payment will be made only after the supply of the items at our own site.
6. The undersigned reserves the right to accept/reject any quotation without assigning any reason.

The sealed quotations should be addressed to "the Registrar, University of Kerala, Senate House Campus, Thiruvananthapuram - 695034 superscribing **"Quotations for the supply of six number of Batteries for the 3 KVA UPS installed in the ground floor of Finance Wing, SH Campus, Palayam "**. The last date for receipt of quotations is at 3.00 PM on 02.09.2026. The quotations will be opened at 3.30 PM on the same day in the presence of Vendors then present.

RESMI R

Registrar



Specification for batteries - 6 nos.

Supply of **12 V, 65 Ah Sealed Maintenance Free (SMF) Batteries** with **interconnecting cables**, having a **minimum warranty of 3 years**, suitable for use with a **3 KVA UPS**. The batteries shall be of **Amaron/Exide/Equivalent** make.

Format of Compliance Statement

Feature	Description	Compliance (Yes/No)	Remarks
Battery - 6 Nos	SMF battery of 65Ah 12V with interconnecting cables		
Battery rack	Required		
Warranty	3 Year		
Preferred brands	AMARON/EXIDE/EQUIVALENT		

