

UNIVERSITY OF KERALA

Thiruvananthapuram, Kerala, India – 695034

(Established as University of Travancore by the Travancore University Act in 1937 and reconstituted as University of Kerala by the Kerala University Act of 1957 and presently governed by the Kerala University Act of 1974 passed by the Kerala State Legislative Assembly)
(Re-accredited by NAAC with 'A++' Grade)

64037/Ad BIV A/2023/UOK

18.11.2024

QUOTATION NOTICE

Competitive Quotations are invited from vendors, within Kerala, for the supply of 22 numbers of 600 VA UPS for the Department of Statistics, with the following specifications.

1. Technology : MOSFET-PWM
2. Inverter Efficiency (%) : 60% or better
3. Warranty : 2 years for UPS & Battery
4. Rating (In KVA) : 0.6 or 0.65 (Choose any)
5. Minimum Guaranteed Battery Backup Time (Minutes) On Full Load : 15 min or above
6. Degree Of Protection : IP 20
7. Rated Output (Volt) With Total Harmonic Distortion (%) : Single phase Quasi sine wave 230V-50Hz
8. Input (Volt) : 160-280V single phase
9. Variation In AVR Output In AC Mode (AVR Voltage Regulation) : 230 Volts +/-9%, 50 +/-3 Hz
10. Location Of Battery : Inside the enclosure of UPS
11. Preferred brands : Numeric, V-Guard, Zebronic, APC

Conditions

1. Complaints with the items supplied should be rectified/replaced to the satisfaction of the University by the suppliers at their own cost.
2. Payment will be made only after the delivery of the item at our site.
3. The undersigned reserves the right to reject / accept any quotation without assigning any reason.
4. Compliance statement should be submitted that includes all parameters as in specification.
5. Suppliers who have not maintained the quality will be blacklisted.
6. Incomplete & conditional quotations and quotations received after the due date will be summarily rejected without assigning any reasons thereof.
7. The price should be inclusive of all taxes, duties, transportation, installation etc. Nothing extra will be paid in addition to the quoted rate.
8. The Price should be quoted only in Indian Rupees.
9. Quotation submitted shall remain valid at least for 90 days from the date of opening



the quotation.

The sealed Quotation along with the Compliance Statement shall be addressed to "The Registrar, University of Kerala, Senate House Campus, Palayam, Trivandrum - 695 034" superscribing : "**Quotation for the supply of 22 numbers of 600 VA UPS for the Department of Statistics**". The last date of receipt of Quotations is at 3:00 pm on 30.11.2024. The Quotations will be opened at 3:30 PM on the same day in the presence of vendors then present.

Compliance Statement

Specify make and model :				
Sl. No.	Description	Parameters	Compliance (Yes / No)	Remarks
1.	Technology	MOSFET-PWM		
2.	Inverter Efficiency (%)	60% or better		
3.	Warranty For Line Interactive UPS	2		
4.	Rating (In KVA)	0.6 or 0.65 (Choose any)		
5.	Minimum Guaranteed Battery Backup Time (Minutes) On Full Load	15 min or above		
6.	Warranty For The Battery From The Date Of Delivery	2		
7.	Degree Of Protection	IP 20		
8.	Rated Output (Volt) With Total Harmonic Distortion (%)	Single phase Quasi sine wave 230V-50Hz		
9.	Input (Volt)	160-280V single phase		
10.	Variation In AVR Output In AC Mode (AVR Voltage Regulation)	230 Volts +/-9%, 50 +/-3 Hz		
11.	Location Of Battery	Inside the enclosure of UPS		
12.	Preferred Brands	V-Guard, Zebronic,APC.		



Registrar

Draft #10 of File 64037/Ad BIV A/2023/UOK Approved by Registrar on 18-Nov-2024 02:51 PM - Page 3



The document is digitally approved. Hence signature is not needed.

