

## **Call for quotation.**

Sealed quotations are invited for a the following equipments with the specifications given, in the Department of Biotechnology, University of Kerala, Kariavattom, Thiruvananthapuram.

### **1. An online UPS with the following specifications**

- **5 KVA online UPS with 2 hour Battery backup time on full load for attaching to ultra low temperature freezer**
- **Battery Type: Tubular battery**
- **Warranty: 3 years for battery and UPS.**

### **2. 5 KVA Servo Stabilizers**

#### **With the following Technical specification**

- Input range should be 170 – 270 V/AC.
- Output voltage should be 230+5% AC.
- With high and low voltage trip circuit.
- Single variac with buckboost transformer.
- Voltmeter to read input and output voltage.
- MCB on input circuit.
- Compact and modular construction for easy handling and servicing.
- Minimum Three year warranty

The quotations addressed to

**The Head, Department of Biotechnology, University of Kerala, Karivattom, Thiruvananthapuram should reach the Department on or before 16<sup>th</sup> July, 2018.**