

UNIVERSITY OF KERALA

Thiruvananthapuram, Kerala, India – 695034

(Established as University of Travancore by the Travancore University Act in 1937 and reconstituted as University of Kerala by the Kerala University Act of 1957 and presently governed by the Kerala University Act of 1974 passed by the Kerala State Legislative Assembly)
(Re-accredited by NAAC with 'A⁺⁺' Grade)

32295/Admn B IV/2022/UOK
25.07.2022

QUOTATION NOTICE

Competitive Quotations are invited from interested vendors inside Kerala for the supply of two numbers of 5 KVA Online UPS for use in the Research Directorate in the University of Kerala.

Conditions

1. The rate quoted should be inclusive of GST, transportation charges, installation charges and any other charges.
2. **Compliance Statement should be submitted that includes all parameters as in specification.**
3. Complaints with the items supplied should be rectified/replaced to the satisfaction of the University by the suppliers at their own cost.
4. Payment will be made only after the supply of the items at our site.
5. The undersigned reserves the right to reject /accept any Quotation without assigning any reason.

The sealed Quotations should be addressed to the Registrar, University of Kerala, Thiruvananthapuram superscribing as '**Quotation for the supply of two numbers of 5KVA Online UPS for use in Research Directorate in the University of Kerala**'. The last date for receipt of quotations is at **03.00PM on 10.08.2022**. The Quotations will be opened at 3.30 PM on the same day in the presence of Vendors then present.

REGISTRAR

SPECIFICATIONS

5KVA UPS Online(2 nos)



SI No	Features	Description
1	Rating in KVA	5.0KVA Online UPS
2	Technology	IGBT- PWM with inbuilt isolation transformer
3	Input Power	Single Phase 160V-260V pure sine wave 50 Hz
4	Output Power	Single phase 230V+-1% pure sine wave 50 Hz
5	Battery Type	65/75 Ah 10 numbers SMF (with rack)
6	Overall Efficiency	>90%
7	Warranty	3 years for UPS&2 years for battery.

Format of Compliance Sheet

SI No	Features	Description	Compliance(Yes/No)	Remarks
1	Rating in KVA	5.0KVA Online UPS		
2	Technology	IGBT- PWM with inbuilt isolation transformer		
3	Input Power	Single Phase 160V-260V pure sine wave 50 Hz		



4	Output Power	Single phase 230V+-1% pure sine wave 50 Hz		
5	Battery Type	65/75 Ah 10 numbers SMF (with rack)		
6	Overall Efficiency	>90%		
7	Warranty	3 years for UPS&2 years for battery.		

